

## KOMO® product certificate K-0224982-1



Issued **01-09-2025** Replaces **-**  
Valid from **-** Page **1 of 3**

### PE-RT Pipes BSI Pipe System SA

#### STATEMENT BY KIWA

This product certificate is based on BRL 5602 Plastics piping systems of PE-RT intended for floor heating issued on 25 October 2016 by Kiwa, issued according to the Kiwa-Regulation for Certification.

The quality system and the product characteristics of this product are checked periodically. Based on this, **Kiwa declares that** there is legitimate confidence that:

Upon delivery, the product supplied by the certificate holder meets the requirements:

- Of the technical specifications laid down in this product certificate,
- The product requirements laid down both in this product certificate and in the Guideline/BRL.

Provided the product is accompanied by the KOMO® quality mark in the manner set out in this product certificate.

Wim van Loon  
Managing Director Nederland

*This product certificate is also included on the KOMO foundation websites: [www.komo.nl](http://www.komo.nl) and [www.komo-online.nl](http://www.komo-online.nl).*

*Users of this product certificate are advised to check whether it is still valid. For this purpose consult the website of Kiwa: [www.kiwa.com](http://www.kiwa.com).*



**Kiwa Nederland B.V.**  
Sir Winston Churchill-  
laan 273  
P.O. Box 70  
2280 AB RIJSWIJK  
The Netherlands  
Tel. +31 88 998 44 00  
[NL.Kiwa.Info@kiwa.com](mailto:NL.Kiwa.Info@kiwa.com)  
[www.kiwa.com](http://www.kiwa.com)

**BSI Pipes System SA**  
Rue George Stephenson 25  
7180 SENEFFE  
Belgium  
Tel. +32 64 236 223  
[www.bsibelgium.be](http://www.bsibelgium.be)



Assessed is:  
• Quality system  
• Product  
Periodic control

## PE-RT pipes

### TECHNICAL SPECIFICATION

#### Subject

5-layer PE-RT (type 2)/EVOH/PE-RT (type 2)

#### Product characteristics

This product certificate relates to the product characteristics of PE-RT pipes in accordance with BRL 5602 Plastics piping systems of PE-RT intended for floor heating

#### Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
16	2,0
20	2,0

Colour: natural

### QUALITY MARK AND INDICATIONS PLACED ON THE PRODUCTS

#### Pipes

- The minimum required marking on the pipes shall be:
- KOMO (or KOMO® word mark) + class 4/ 6 bar;
- material identification: PE-RT (type 2);
- the buildup of the pipe: PE-RT (type 2)/EVOH/PE-RT (type 2);
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2 meters.

#### Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

### PRODUCT CHARACTERISTICS

The product complies to the in BRL 5602 Plastics piping systems of PE-RT intended for floor heating recorded product requirements

### APPLICATION AND USE

The products are intended to be used for piping systems for floor heating systems with a lifetime of 50 years at an operating temperature profile according to class 4 of ISO 10508 and an allowable working pressure of maximum 6 bar.

### RECOMMENDATIONS FOR THE CUSTOMERS

Check on delivery of the products listed under the "technical specification" whether:

- The product(s) and material(s) ordered are delivered in accordance with the agreement you made.
- The brand and the method of marking is correct
- No defects or damage is visible (for example, resulting from the transportation).



## PE-RT pipes

---

If on the basis of the foregoing you decide to proceed to rejection, please contact

- BSI Pipe system SA

And if necessary,

- Kiwa Nederland B.V.

Follow the application conditions and processing instructions included in this product certificate and belonging attestation and/or documents of the certificate holder.



## BSI PIPE SYSTEMS

## BSI Pipe system SA

### STATEMENT BY KIWA

This technical approval-with-product certificate on the basis of BRL 5602 Plastics piping systems of PE-RT intended for floor heating issued on 25 October 2016 by Kiwa, in accordance with the Kiwa Regulation for Certification.

The quality system and the product characteristics belonging to the PE-RT system are checked periodically and the performance of the PE-RT system in the application as floor heating is assessed. The basic principles for the assessment are checked periodically.

Based on this Kiwa declares that:

- legitimate confidence exists that the by the holder of the technical approval- with-product certificate delivered PE-RT systems comply with:
  - the technical specifications as laid down in this technical approval-with-product certificate;
  - the product requirements as laid down in this technical approval-with-product certificate, provided that they have been marked the PE-RT system with the KOMO®-mark in the manner as indicated in this technical approval-with-product certificate;
- the PE-RT system provides the performances as described in this KOMO technical approval-with-product certificate, provided that:
  - the application conditions and technical specifications as described in this KOMO approval-with-product certificate are met;
  - the manufacturing takes place according to the processing methods as laid down in this technical approval-with-product certificate.

Within the framework of this KOMO technical approval-with-product certificate there is no inspections with regard to the production of other parts of the PE-RT system or the processing of the PE-RT system.



Wim van Loon  
Managing Director Nederland

*This Technical approval-with-product certificate is also included on the KOMO foundation websites: [www.komo.nl](http://www.komo.nl) and [www.komo-online.nl](http://www.komo-online.nl). Users of this Technical approval-with-product certificate is advised to check whether it is still valid. For this purpose consult the website of Kiwa: [www.kiwa.com](http://www.kiwa.com).*

## BSI PIPE SYSTEMS

### TECHNICAL SPECIFICATION

#### Subject

BSI PIPE SYSTEMS

#### Product characteristics

The product complies to BRL 5602 Plastics piping systems of PE-RT intended for floor heating.

The system consists of:

- PE-RT/EVOH/PE-RT pipes, manufactured by BSI Pipe system SA (certificate K-0224982)
- Metal press fittings (profile TH), manufactured by Valsir SpA (certificate K22567)

#### Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
16	2,0
20	2,0

Colour Pipe: natural

Colour Fitting: brass

**Remarks: metal press fittings with press profile TH**

#### Marking

The products shall be marked with the KOMO® mark.

#### Pipes

The minimum required marking on the pipes shall be:

- The minimum required marking on the pipes shall be:
- KOMO (or KOMO® word mark) + class 4/ 6 bar;
- material identification: PE-RT type 2;
- the buildup of the pipe: PE-RT/EVOH/PE-RT;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clearly, durable and indelible at intervals of not more than 2 meters.

#### Fittings

The minimum required marking on the fittings shall be:

- KOMO (if not possible KOMO only on the smallest packaging);
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.

The realization of the marks is as follows: clearly, durable and indelible.

The minimum required marking on the smallest packaging unit of the fitting shall be:

- KOMO (or KOMO® word mark);
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;



## BSI PIPE SYSTEMS

---

- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

The realization of the marks is as follows: clearly, durable and indelible.

### Logistics

Production and assembly of the system is laid down in the annex of the certification agreement.

### PROCESSING

The supplier shall provide installation instructions, approved by Kiwa. A reference to these instructions shall be made at or near the packaging. The instructions are published in the Dutch language and contains at least specific information with regard to storage, transport, processing temperature and construction of the joints.

So-called "combination boilers" are often applied in individual house heating systems. In such boilers, no double separation between drinking water and heating medium exists. A leak in the single separation may result in the heating medium coming into contact with drinking water. In relation to this the requirement is that in case additives are added to the heating medium these additives have to comply with the Dutch drinking water regulations.

The heat emission to the floor is dependent on the thickness of the finishing coat and the mutual distance between the pipes. The preconditions have to be clearly described in the instructions.

### PERFORMANCES

1. The system is oxygen tight.
2. All joints are leak tight and possess sufficient clamp force to resist external influences.

### PERFORMANCES OF THE PRODUCTS

All the products of the system are designed for a lifetime of 50 years at an operating temperature profile according to class 4 of NEN-ISO 10508 and an allowable working pressure of maximum 6 bar.

### RECOMMENDATIONS FOR THE CUSTOMER

Check on delivery of the products listed under the "technical specification" whether:

- The product(s) and material(s) ordered are delivered in accordance with the agreement you made.
- The brand and the method of marking is correct
- No defects or damage is visible (for example, resulting from the transportation).

In the context of this product certificate with attestation, no checks take place on the accuracy of the performance of the essential characteristics.

The statements in this product certificate with attestation may not be used to replace the CE marking and/or the corresponding obligatory Declaration of Performance.

If on the basis of the foregoing you decide to proceed to rejection, please contact

- BSI Pipe system SA

And if necessary,

- Kiwa Nederland B.V.

Carry out the storage, transport and processing in accordance with the provisions included in this technical approval-with-product certificate and/or documents of the certificate holder.

